

CITY OF PLATTSBURG

SIDEWALK REPLACEMENT SPECIFICATIONS

1. SIDEWALKS TO BE A MINIMUM OF 4" (FOUR INCHES) THICK.
2. SIDEWALKS TO BE A MINIMUM OF 6" (SIX INCHES) THICK AT DRIVEWAY.
3. SIDEWALKS TO BE A MINIMUM OF 8" (EIGHT INCHES) THICK AT ALLEYS & COMMERCIAL DRIVEWAYS.
4. SIDEWALKS TO BE A MINIMUM OF 36" (THIRTY SIX INCHES) WIDE OR WHAT CURRENTLY EXIST.
5. CONCRETE FOR SIDEWALKS IS TO BE NOT LESS THAN 3000 POUND MIX.
6. SLAB LENGTH SHALL EQUAL SLAB WIDTH.
7. CONCRETE JOINTS SHALL SEPARATE ALL SLABS.
8. CONCRETE JOINTS SHALL BE CUT AT LEAST 1/3 (ONE THIRD) OF THE SLAB THICKNESS.
9. EXPANSION JOINTS 1/2" (ONE HALF INCH) IN THICKNESS SHALL BE PROVIDED AT ALL INTERSECTING CURBS, SIDEWALKS, DRIVEWAYS & BUILDINGS.
10. ALL SIDEWALKS SHALL CONTAIN STEEL REINFORCING.
11. ALL SIDEWALKS SHALL HAVE A 3-4" (THREE-FOUR INCH) CLEAN GRAVEL BASE.
12. ALL SIDEWALKS ARE TO BE WHEEL CHAIR ACCESSIBLE.
13. IF A FILL IS MADE IT WILL BE MADE OF REGULAR SURFACE ROCK & NOT EARTH.
14. SIDEWALK SHALL BE BROOM FINISHED & NEVER TROWLED.